

Civil Engineering

***THE FIRE PROTECTION OPERATIONS AND
FIRE PREVENTION PROGRAM***

AFI 32-2001, 1 April 1999, is supplemented as follows:

This supplement applies to all Air National Guard (ANG) Fire Protection personnel. This includes all personnel employed by the ANG to provide fire protection services, such as State Master Cooperative Agreement (MCA) fire fighters.

1.4. The Civil Engineer of the ANG (ANG/CE) will execute the fire protection and prevention policy for the ANG. ANG/CEXF is the MAJCOM office for ANG fire protection.

1.6. The Fire Chief refers to the Technician Fire Chief who is responsible for installation protection. In a Title V Fire Department, the Title V Fire Chief fills this responsibility.

2.1. A full-time fire department will be established at those installations identified by the Civil Engineer, ANG/CE. Other sites will rely on the fire protection agencies (civilian or military) that have jurisdiction in their areas.

2.2. The Civil Engineer, ANG/CE, will determine manpower and equipment authorizations for full-time fire departments.

3.1.1. Requests for waivers will be submitted through ANG/CEXF, 3500 Fetchet Ave., Andrews AFB, MD 20762-5157.

3.1.2. ANG/CE will determine manpower standards and equipage for the ANG.

3.1.4. NGR 5-1/ANGI 63-101 (Interim), *Grants and Cooperative Agreements*, Chapter 36, "ANG Fire Protection," prescribes the wear of the fire protection badge for MCA fire fighters.

3.2.2. Traditional Guard fire fighters are subject to the provisions of this paragraph upon Federal activation only.

3.3.9. The terms "USAF senior fire official," and "Air Force fire fighter," also apply to any member of an ANG fire department.

3.3.12. Any fire department having mutual aid or reciprocal agreements with surrounding jurisdictions must have radio communications with that agency. ANG fire departments located on civil aviation airports must have radio communications with the Ground Control/Air Traffic Control Tower Operators.

3.4.5. (Added) (ANG) Provide a listing of the top ten Fire Safety Deficiencies to ANG/CEXF annually (report due in January of each year) in the format specified by that office.

3.7. Base Civil Engineers will ensure that the fire department is provided an opportunity to review any RPM or MCP projects for fire and life safety issues. This is required since ANG installations normally do not have a Fire Protection Engineer on staff.

4. ANG units, add the following forms:
AF Form 1800, **Series Vehicle Cards**.

Attachment 1

References

ANGRC Publications: (Added) (ANG)

Current ANG Engineering Technical Letters

NGB Publications: (Added) (ANG)

NGR 5-1/ANGI 63-101 (Interim), *Grants and Cooperative Agreements*

Other:

NFPA Standard 1582, *Medical Requirements for Fire Fighters*

Abbreviations and Acronyms

ANG – Air National Guard

ANGRC – Air National Guard Readiness Center

ANG/CEXF – Office of the Chief, Air National Guard Fire Protection

BCE – Base Civil Engineer

O&M – Operations & Maintenance

MCA – Master Cooperative Agreement

MCA Fire Fighter – Any employee hired to perform fire protection/prevention functions under the auspices of the Master Cooperative Agreement.

RPM – Real Property Maintenance

TAG – The Adjutant General

USP&FO – United States Property and Fiscal Officer

Attachment 2

A2.2.15. First sentence, in parenthesis, change “twice” to read “once”.

Attachment 3

A3.1.1. The Fire Chief will report any incident meeting the criteria as identified in A3.1.1. to ANG/CEXF, DSN 278-8165/8170, Commercial (301) 836-8165/8170 or to the ANG Command Post (if after CEXF duty hours, 0730 – 1630 Eastern Standard Time, Monday through Friday), DSN 858-6001, Commercial (301) 981-6001, FAX DSN 858-7505. ANG/CEXF will, in turn, up channel the information to HQ AFCESA/CEXF.

A3.2.1. The MAJCOM FPO refers to ANG/CEXF.

Figure A3.1. Replace “MAJCOM//FOA//FPO” with:
ANG ANDREWS AFB MD//CEXF//

Attachment 4

Add the following signature blocks to any agreement:

USP&FO for (State)

Responsible Civil Agency for the Fire
Organization

TAG (State)
(Add TAG if State MCA fire fighters
are included)

The Civil Engineer for Chief
National Guard Bureau

Attachment 6

Release of Claims and Indemnification Clause for Civil Airport Joint-Use-Agreements will read as follows for ANG installations:

(Name of Airport Operator) agrees to release, acquit, and forever discharge the United States, its officers, agents, employees and State of (STATE) employees for all liability arising out of or connected with the use of United States equipment, personnel, State of (STATE) employees, for fire control, crash, and rescue activities at or in the vicinity of (name of airport), and (name of airport operator) further agrees to indemnify, defend, and hold harmless the United States its officers, agents, employees, and State of (STATE) employees against any and all claims, of whatever description, arising out of or connected with such use of United Sates equipment or personnel, and State of (STATE) employees. The agreements contained in the preceding sentence do not extend to claims arising out of or connected with services rendered solely for the protection of United States property, personnel, or State of (STATE) employees, or to claims for damages caused solely by the negligence or willful misconduct of officers, agents, employees of the United States or State of (STATE) employees, without contributory fault on the part of any person, firm, or corporation; provided; however, that insofar as this paragraph may be consistent with the waiver or claims provisions contained in any reciprocal agreement for mutual aid in furnishing fire protection heretofore or hereafter entered into by the lessor with any agency of the United States pursuant to Public Law 84-46 (42 USC 1856, et seq.), the rights and obligations of the parties shall be governed by said waiver of claims provision and not by this paragraph.

PAUL A. WEAVER, JR.
Major General, USAF
Director, Air National Guard

OFFICIAL

DEBORAH GILMORE
Chief
Administrative Services

Attachment
8. ANG Suspense Listing (Added) (ANG)

Attachment 8 (Added) (ANG)**AIR NATIONAL GUARD SUSPENSE LISTING**

<u>Reporting Requirement</u>	<u>Freq</u>	<u>To Arrive At/When Due</u>
Fire Department Response Report	M	To Respective Zone Director , not later than the 10 th of each month
DoD Fire Incident Reporting System	Q	US Naval Safety Center, no less than quarterly
Vehicle Listing/Mileage Report	Sa	ANG/CEXF, Jan & Jul not later than the 15 th
Halon 1211 & 1301 Report	Sa	111 CES/CEF, Jan & Jul not later than the 15 th
MCA Budget Submittal	A	ANG/CEXF, not later than 1 May
Top 10 Fire Safety Deficiencies	A	ANG/CEXF, not later than 15 Jan
NFPA 1500 Worksheet & ORM Plans for Deficiencies	A	ANG/CEXF, not later than 1 Aug